Program Version:**EnergyPlus, Version 9.5.0-de239b2e5f, YMD=2021.07.11 21:50**

Table of Contents

Tabular Output Report in Format: **HTML**

Building: **CentroCirurgico**

Environment: **RUN PERIOD 1 ** BRASILIA_(CIV/MIL) - BRA SWERA WMO#=833780**

Simulation Timestamp: **2021-07-11 21:50:38**

Table of Contents

Top
Input Verification and Results Summary
Climatic Data Summary
Envelope Summary

SpaceGainsMonthly

| CIRCENT | CIRCPERIF | DEPOSITO | ESTARPESSOAL | EXPURGO | HALL | HOMVESTAUX | MATANEST | POSTOENF | RECUPPOSANEST | REPFEM | REPMASC | ROUPASUJA | ROUPARIA | SOP1 | SOP2 | SOP3 | SOP4 | SOP5 | SOP6 | SOP7 | SOP8 | SALA | SALAAUXILIAR | SALAGESSO | SECCONTROLE | VESTFEM | VESTMASC | WCVESTMASC |

Report: **Input Verification and Results Summary**

Table of Contents

For: **Entire Facility**

Timestamp: **2021-07-11 21:50:38**

General

	Value
Program Version and Build	EnergyPlus, Version 9.5.0-de239b2e5f, YMD=2021.07.11 21:50
RunPeriod	RUN PERIOD 1
Weather File	BRASILIA_(CIV/MIL) - BRA SWERA WMO#=833780
Latitude [deg]	-15.9
Longitude [deg]	-47.9
Elevation [m]	1061.00
Time Zone	-3.0
North Axis Angle [deg]	-90.0
Rotation for Appendix G [deg]	0.00
Hours Simulated [hrs]	8760.00

ENVELOPE

Window-Wall Ratio

	Total	North (315 to 45 deg)	East (45 to 135 deg)	South (135 to 225 deg)	West (225 to 315 deg)
Gross Wall Area [m2]	2588.33	596.45	697.71	596.45	697.71
Above Ground Wall Area [m2]	2588.33	596.45	697.71	596.45	697.71
Window Opening Area [m2]	0.00	0.00	0.00	0.00	0.00
Gross Window-Wall Ratio [%]	0.00	0.00	0.00	0.00	0.00
Above Ground Window-Wall Ratio [%]	0.00	0.00	0.00	0.00	0.00

Conditioned Window-Wall Ratio

	Total	North (315 to 45 deg)	East (45 to 135 deg)	South (135 to 225 deg)	West (225 to 315 deg)
Gross Wall Area [m2]	2156.24	457.61	620.51	457.61	620.51
Above Ground Wall Area [m2]	2156.24	457.61	620.51	457.61	620.51
Window Opening Area [m2]	0.00	0.00	0.00	0.00	0.00
Gross Window-Wall Ratio [%]	0.00	0.00	0.00	0.00	0.00
Above Ground Window-Wall Ratio [%]	0.00	0.00	0.00	0.00	0.00

Skylight-Roof Ratio

	Total
Gross Roof Area [m2]	1097.96
Skylight Area [m2]	0.00

Skylight-Roof Ratio [%]	0.00

PERFORMANCE

Zone Summary

	Area [m2]	Conditioned (Y/N)	Part of Total Floor Area (Y/N)	Volume [m3]	Multipliers	Above Ground Gross Wall Area [m2]	Underground Gross Wall Area [m2]	Window Glass Area [m2]	Opening Area [m2]	Lighting [W/m2]	People [m2 per person]	Plug and Process [W/m2]
CIRCENT	17.65	Yes	Yes	52.96	1.00	62.82	0.00	0.00	0.00	10.6563	4.00	7.6424
CIRCPERIF	336.43	Yes	Yes	1009.30	1.00	773.06	0.00	0.00	0.00	10.6563	4.00	7.6424
DEPOSITO	13.82	No	Yes	41.46	1.00	63.48	0.00	0.00	0.00	10.6563	4.00	7.6424
ESTARPESSOAL	7.77	Yes	Yes	23.30	1.00	33.82	0.00	0.00	0.00	10.6563	4.00	7.6424
EXPURGO	15.86	No	Yes	47.57	1.00	54.04	0.00	0.00	0.00	10.6563	4.00	7.6424
HALL	52.38	Yes	Yes	157.14	1.00	141.24	0.00	0.00	0.00	10.6563	4.00	7.6424
HOMVESTAUX	15.86	No	Yes	47.57	1.00	54.04	0.00	0.00	0.00	10.6563	4.00	7.6424
MATANEST	16.61	Yes	Yes	49.82	1.00	61.66	0.00	0.00	0.00	10.6563	4.00	7.6424
POSTOENF	17.54	Yes	Yes	52.62	1.00	58.50	0.00	0.00	0.00	10.6563	4.00	7.6424
RECUPPOSANEST	114.54	Yes	Yes	343.63	1.00	137.88	0.00	0.00	0.00	10.6563	4.00	7.6424
REPFEM	21.57	Yes	Yes	64.72	1.00	55.80	0.00	0.00	0.00	10.6563	4.00	7.6424
REPMASC	17.76	Yes	Yes	53.29	1.00	58.68	0.00	0.00	0.00	10.6563	4.00	7.6424
ROUPARIA	7.64	No	Yes	22.91	1.00	33.58	0.00	0.00	0.00	10.6563	4.00	7.6424
ROUPASUJA	15.72	No	Yes	47.17	1.00	53.92	0.00	0.00	0.00	10.6563	4.00	7.6424
SALA	8.16	Yes	Yes	24.47	1.00	34.54	0.00	0.00	0.00	10.6563	4.00	7.6424
SALAAUXILIAR	15.04	Yes	Yes	45.12	1.00	47.58	0.00	0.00	0.00	10.6563	4.00	7.6424
SALAGESSO	35.01	Yes	Yes	105.02	1.00	72.72	0.00	0.00	0.00	10.6563	4.00	7.6424
SECCONTROLE	9.72	Yes	Yes	29.17	1.00	42.12	0.00	0.00	0.00	10.6563	4.00	7.6424
SOP1	32.37	Yes	Yes	97.11	1.00	69.04	0.00	0.00	0.00	10.6563	4.00	7.6424
SOP2	31.69	Yes	Yes	95.07	1.00	68.42	0.00	0.00	0.00	10.6563	4.00	7.6424
SOP3	31.25	Yes	Yes	93.74	1.00	68.02	0.00	0.00	0.00	10.6563	4.00	7.6424
SOP4	31.60	Yes	Yes	94.80	1.00	68.34	0.00	0.00	0.00	10.6563	4.00	7.6424
SOP5	31.78	Yes	Yes	95.33	1.00	68.50	0.00	0.00	0.00	10.6563	4.00	7.6424
SOP6	44.37	Yes	Yes	133.10	1.00	80.34	0.00	0.00	0.00	10.6563	4.00	7.6424
SOP7	44.29	Yes	Yes	132.88	1.00	80.28	0.00	0.00	0.00	10.6563	4.00	7.6424
SOP8	35.23	Yes	Yes	105.69	1.00	72.90	0.00	0.00	0.00	10.6563	4.00	7.6424
VESTFEM	40.72	No	Yes	122.15	1.00	77.37	0.00	0.00	0.00	10.6563	4.00	7.6424
VESTMASC	31.58	No	Yes	94.73	1.00	68.32	0.00	0.00	0.00	10.6563	4.00	7.6424
WCVESTMASC	4.01	No	Yes	12.03	1.00	27.36	0.00	0.00	0.00	10.6563	4.00	7.6424
Total	1097.96			3293.87		2588.33	0.00	0.00	0.00	10.6563	4.00	7.6424
Conditioned Total	952.76			2858.29		2156.24	0.00	0.00	0.00	10.6563	4.00	7.6424
Unconditioned Total	145.19			435.58		432.10	0.00	0.00	0.00	10.6563	4.00	7.6424
Not Part of Total	0.00			0.00		0.00	0.00	0.00	0.00			

Report: **Climatic Data Summary**

Table of Contents

For: **Entire Facility**

Timestamp: **2021-07-11 21:50:38**

SizingPeriod:DesignDay

	Maximum Dry Bulb [C]	Daily Temperature Range [deltaC]	Humidity Value	Humidity Type	Wind Speed [m/s]	Wind Direction
None						

Weather Statistics File

	Value
None	

Report: **Envelope Summary**

Table of Contents

For: **Entire Facility**

Timestamp: **2021-07-11 21:50:38**

Opaque Exterior

	Construction	Reflectance	U-Factor with Film [W/m2-K]	U-Factor no Film [W/m2-K]	Gross Area [m2]	Net Area [m2]	Azimuth [deg]	Tilt [deg]	Cardinal Direction
SURFACE 153	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	8.52	6.67	180.00	90.00	S
SURFACE 154	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	3.63	3.63	270.00	90.00	W
SURFACE 155	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.56	7.56	270.00	90.00	W
SURFACE 156	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.20	7.20	270.00	90.00	W
SURFACE 157	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	4.50	4.50	270.00	90.00	W
SURFACE 158	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	2.97	2.97	0.00	90.00	N
SURFACE 159	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	6.51	6.51	90.00	90.00	E
SURFACE 160	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	5.55	5.55	0.00	90.00	N
SURFACE 161	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.33	9.33	90.00	90.00	E
SURFACE 162	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.05	7.05	90.00	90.00	E
SURFACE 152	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	17.65	17.65	270.00	180.00	
SURFACE 163	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	15.51	15.51	270.00	0.00	
SURFACE 263	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	2.15	2.15	270.00	0.00	
SURFACE 205	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.28	14.28	90.00	90.00	E
SURFACE 206	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	94.01	94.01	90.00	90.00	E
SURFACE 207	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	65.54	65.54	180.00	90.00	S
SURFACE 208	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 1	0.08	2.654	4.404	97.52	97.52	270.00	90.00	W
SURFACE 209	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 1	0.08	2.654	4.404	7.83	7.83	0.00	90.00	N
SURFACE 210	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	11.01	11.01	90.00	90.00	E
SURFACE 211	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.14	7.14	90.00	90.00	E
SURFACE 212	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.43	14.43	90.00	90.00	E
SURFACE 213	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.35	14.35	90.00	90.00	E
SURFACE 214	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.19	14.19	90.00	90.00	E
SURFACE 215	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.39	14.39	90.00	90.00	E
SURFACE 216	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.70	14.70	90.00	90.00	E
SURFACE 217	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	0.00	90.00	N
SURFACE 218	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.70	14.70	270.00	90.00	W
SURFACE 219	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.39	14.39	270.00	90.00	W
SURFACE 220	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.19	14.19	270.00	90.00	W

SURFACE 221	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.35	14.35	270.00	90.00	W
SURFACE 222	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.43	14.43	270.00	90.00	W
SURFACE 223	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.14	7.14	270.00	90.00	W
SURFACE 224	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.08	7.08	270.00	90.00	W
SURFACE 225	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	3.93	3.93	270.00	90.00	W
SURFACE 226	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.20	7.20	270.00	90.00	W
SURFACE 227	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	3.57	3.57	270.00	90.00	W
SURFACE 228	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	8.52	8.52	0.00	90.00	N
SURFACE 229	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.56	7.56	90.00	90.00	E
SURFACE 230	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.14	7.14	90.00	90.00	E
SURFACE 231	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.23	7.23	90.00	90.00	E
SURFACE 232	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.25	14.25	90.00	90.00	E
SURFACE 233	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.34	14.34	90.00	90.00	E
SURFACE 234	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 1	0.08	2.654	4.404	18.03	18.03	90.00	90.00	E
SURFACE 235	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.53	7.53	0.00	90.00	N
SURFACE 236	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.37	14.37	90.00	90.00	E
SURFACE 237	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.53	7.53	180.00	90.00	S
SURFACE 238	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	18.06	18.06	90.00	90.00	E
SURFACE 239	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	22.11	22.11	0.00	90.00	N
SURFACE 240	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	18.06	18.06	270.00	90.00	W
SURFACE 241	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	5.16	5.16	180.00	90.00	S
SURFACE 242	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.37	14.37	270.00	90.00	W
SURFACE 243	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	5.16	5.16	0.00	90.00	N
SURFACE 244	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	18.03	18.03	270.00	90.00	W
SURFACE 245	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.34	14.34	270.00	90.00	W
SURFACE 246	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.25	14.25	270.00	90.00	W
SURFACE 247	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.23	7.23	270.00	90.00	W
SURFACE 248	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.14	7.14	270.00	90.00	W
SURFACE 249	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	8.82	8.82	180.00	90.00	S
SURFACE 250	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.56	7.56	270.00	90.00	W
SURFACE 251	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	8.82	8.82	0.00	90.00	N
SURFACE 252	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.26	7.26	0.00	90.00	N
SURFACE 204	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	336.43	336.43	270.00	180.00	
SURFACE 253	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	13.51	13.51	270.00	0.00	

SURFACE 265	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	49.20	49.20	270.00	0.00	
SURFACE 266	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	19.83	19.83	270.00	0.00	
SURFACE 267	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	20.46	20.46	270.00	0.00	
SURFACE 268	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	17.96	17.96	270.00	0.00	
SURFACE 269	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	102.51	102.51	270.00	0.00	
SURFACE 270	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	16.10	16.10	270.00	0.00	
SURFACE 271	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	12.02	12.02	270.00	0.00	
SURFACE 272	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	84.84	84.84	270.00	0.00	
SURFACE 173	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.05	7.05	270.00	90.00	W
SURFACE 174	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	8.82	8.82	0.00	90.00	N
SURFACE 175	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.05	7.05	90.00	90.00	E
SURFACE 176	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	8.82	8.82	180.00	90.00	S
SURFACE 179	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.05	7.05	270.00	90.00	W
SURFACE 180	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	8.82	8.82	0.00	90.00	N
SURFACE 181	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.05	5.41	90.00	90.00	E
SURFACE 182	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	8.82	8.82	180.00	90.00	S
SURFACE 172	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	6.91	6.91	270.00	180.00	
SURFACE 178	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	6.91	6.91	270.00	180.00	
SURFACE 184	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	0.00	0.00	270.00	180.00	
SURFACE 177	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	6.91	6.91	270.00	0.00	
SURFACE 183	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	6.91	6.91	270.00	0.00	
SURFACE 107	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.71	9.71	180.00	90.00	S
SURFACE 108	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	3.57	3.57	270.00	90.00	W
SURFACE 109	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	3.63	3.63	270.00	90.00	W
SURFACE 110	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.71	9.71	0.00	90.00	N
SURFACE 111	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	3.63	1.43	90.00	90.00	E
SURFACE 112	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	3.57	3.57	90.00	90.00	E
SURFACE 106	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	7.77	7.77	270.00	180.00	
SURFACE 113	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	7.77	7.77	270.00	0.00	
SURFACE 121	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.71	9.71	180.00	90.00	S
SURFACE 122	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	10.11	10.11	180.00	90.00	S
SURFACE 123	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 1	0.08	2.654	4.404	7.20	5.77	270.00	90.00	W
SURFACE 124	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	0.00	90.00	N
SURFACE 125	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.20	5.14	90.00	90.00	E

SURFACE 120	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	15.86	15.86	270.00	180.00	
SURFACE 126	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	15.86	15.86	270.00	0.00	
SURFACE 186	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	32.73	32.73	90.00	90.00	E
SURFACE 187	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.26	7.26	180.00	90.00	S
SURFACE 188	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	23.62	23.62	270.00	90.00	W
SURFACE 189	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	22.11	22.11	180.00	90.00	S
SURFACE 190	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	5.30	5.30	270.00	90.00	W
SURFACE 191	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	8.52	8.52	180.00	90.00	S
SURFACE 192	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	3.81	3.81	270.00	90.00	W
SURFACE 193	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	37.89	34.95	0.00	90.00	N
SURFACE 185	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	52.38	52.38	270.00	180.00	
SURFACE 194	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	16.04	16.04	270.00	0.00	
SURFACE 273	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	17.28	17.28	270.00	0.00	
SURFACE 274	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	19.06	19.06	270.00	0.00	
SURFACE 100	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	180.00	90.00	S
SURFACE 101	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 1	0.08	2.654	4.404	7.20	7.20	270.00	90.00	W
SURFACE 102	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	10.11	8.89	0.00	90.00	N
SURFACE 103	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.71	9.71	0.00	90.00	N
SURFACE 104	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.20	7.20	90.00	90.00	E
SURFACE 99	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	15.86	15.86	270.00	180.00	
SURFACE 105	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	15.86	15.86	270.00	0.00	
SURFACE 92	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 1	0.08	2.654	4.404	11.01	9.19	270.00	90.00	W
SURFACE 93	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	0.00	90.00	N
SURFACE 94	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	3.93	2.08	90.00	90.00	E
SURFACE 95	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.71	9.71	180.00	90.00	S
SURFACE 96	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.08	7.08	90.00	90.00	E
SURFACE 97	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	10.11	10.11	180.00	90.00	S
SURFACE 91	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	16.61	16.61	270.00	180.00	
SURFACE 264	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	4.24	4.24	270.00	0.00	
SURFACE 98	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	12.37	12.37	270.00	0.00	
SURFACE 72	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.14	7.14	270.00	90.00	W
SURFACE 73	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	13.29	13.29	0.00	90.00	N
SURFACE 74	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	8.82	7.54	0.00	90.00	N
SURFACE 75	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.14	7.14	90.00	90.00	E

SURFACE 76	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	22.11	22.11	180.00	90.00	S
SURFACE 71	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	17.54	17.54	270.00	180.00	
SURFACE 77	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	17.54	17.54	270.00	0.00	
SURFACE 198	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 1	0.08	2.654	4.404	47.01	47.01	90.00	90.00	E
SURFACE 199	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	21.93	21.93	180.00	90.00	S
SURFACE 200	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.28	12.22	270.00	90.00	W
SURFACE 201	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	32.73	29.79	270.00	90.00	W
SURFACE 202	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	21.93	21.93	0.00	90.00	N
SURFACE 197	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	114.54	114.54	270.00	180.00	
SURFACE 203	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	114.54	114.54	270.00	0.00	
SURFACE 165	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.56	5.71	270.00	90.00	W
SURFACE 166	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.05	7.05	270.00	90.00	W
SURFACE 167	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	13.29	13.29	0.00	90.00	N
SURFACE 168	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.05	7.05	90.00	90.00	E
SURFACE 169	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.56	7.56	90.00	90.00	E
SURFACE 170	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	13.29	13.29	180.00	90.00	S
SURFACE 164	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	21.57	21.57	270.00	180.00	
SURFACE 171	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	21.57	21.57	270.00	0.00	
SURFACE 66	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	22.11	22.11	180.00	90.00	S
SURFACE 67	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.23	7.23	270.00	90.00	W
SURFACE 68	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	22.11	22.11	0.00	90.00	N
SURFACE 69	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.23	7.23	90.00	90.00	E
SURFACE 65	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	17.76	17.76	270.00	180.00	
SURFACE 70	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	17.76	17.76	270.00	0.00	
SURFACE 86	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.08	5.23	90.00	90.00	E
SURFACE 87	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.71	9.71	180.00	90.00	S
SURFACE 88	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.08	7.08	270.00	90.00	W
SURFACE 89	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.71	9.71	0.00	90.00	N
SURFACE 85	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	7.64	7.64	270.00	180.00	
SURFACE 90	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	7.64	7.64	270.00	0.00	
SURFACE 79	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.14	5.29	90.00	90.00	E
SURFACE 80	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	180.00	90.00	S
SURFACE 81	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 1	0.08	2.654	4.404	7.14	5.29	270.00	90.00	W
SURFACE 82	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	10.11	10.11	0.00	90.00	N

SURFACE 83	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.71	9.71	0.00	90.00	N
SURFACE 78	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	15.72	15.72	270.00	180.00	
SURFACE 84	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	15.72	15.72	270.00	0.00	
SURFACE 115	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.56	7.56	270.00	90.00	W
SURFACE 116	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.71	9.71	0.00	90.00	N
SURFACE 117	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.56	5.71	90.00	90.00	E
SURFACE 118	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.71	9.71	180.00	90.00	S
SURFACE 114	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	8.16	8.16	270.00	180.00	
SURFACE 119	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	8.16	8.16	270.00	0.00	
SURFACE 54	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.37	12.31	270.00	90.00	W
SURFACE 55	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.42	9.42	0.00	90.00	N
SURFACE 56	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.37	14.37	90.00	90.00	E
SURFACE 57	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.42	9.42	180.00	90.00	S
SURFACE 53	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	15.04	15.04	270.00	180.00	
SURFACE 58	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	15.04	15.04	270.00	0.00	
SURFACE 60	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.25	11.38	90.00	90.00	E
SURFACE 61	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	22.11	22.11	180.00	90.00	S
SURFACE 62	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.25	14.25	270.00	90.00	W
SURFACE 63	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	22.11	22.11	0.00	90.00	N
SURFACE 59	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	35.01	35.01	270.00	180.00	
SURFACE 64	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	35.01	35.01	270.00	0.00	
SURFACE 136	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	5.30	5.30	90.00	90.00	E
SURFACE 137	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.24	7.24	90.00	90.00	E
SURFACE 138	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	5.55	3.92	180.00	90.00	S
SURFACE 139	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	6.51	6.51	270.00	90.00	W
SURFACE 140	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	2.97	2.97	180.00	90.00	S
SURFACE 141	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	6.03	6.03	270.00	90.00	W
SURFACE 142	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	8.52	8.52	0.00	90.00	N
SURFACE 135	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	9.72	9.72	270.00	180.00	
SURFACE 143	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	1.99	1.99	270.00	0.00	
SURFACE 262	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	7.73	7.73	270.00	0.00	
SURFACE 2	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.70	12.85	90.00	90.00	E
SURFACE 3	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	180.00	90.00	S
SURFACE 4	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.70	11.83	270.00	90.00	W

SURFACE 5	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	0.00	90.00	N
SURFACE 1	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	32.37	32.37	270.00	180.00	
SURFACE 6	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	32.37	32.37	270.00	0.00	
SURFACE 10	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.39	12.54	90.00	90.00	E
SURFACE 11	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	180.00	90.00	S
SURFACE 8	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.39	11.52	270.00	90.00	W
SURFACE 9	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	0.00	90.00	N
SURFACE 7	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	31.69	31.69	270.00	180.00	
SURFACE 12	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	31.69	31.69	270.00	0.00	
SURFACE 14	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.19	12.34	90.00	90.00	E
SURFACE 15	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	180.00	90.00	S
SURFACE 16	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.19	11.32	270.00	90.00	W
SURFACE 17	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	0.00	90.00	N
SURFACE 13	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	31.25	31.25	270.00	180.00	
SURFACE 18	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	31.25	31.25	270.00	0.00	
SURFACE 20	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.35	12.50	90.00	90.00	E
SURFACE 21	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	180.00	90.00	S
SURFACE 22	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 1	0.08	2.654	4.404	14.35	11.48	270.00	90.00	W
SURFACE 23	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	0.00	90.00	N
SURFACE 19	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	31.60	31.60	270.00	180.00	
SURFACE 24	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	31.60	31.60	270.00	0.00	
SURFACE 26	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 1	0.08	2.654	4.404	14.43	11.56	270.00	90.00	W
SURFACE 27	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	0.00	90.00	N
SURFACE 28	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.43	12.58	90.00	90.00	E
SURFACE 29	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	180.00	90.00	S
SURFACE 25	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	31.78	31.78	270.00	180.00	
SURFACE 30	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	31.78	31.78	270.00	0.00	
SURFACE 32	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	18.06	15.19	90.00	90.00	E
SURFACE 33	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	22.11	22.11	180.00	90.00	S
SURFACE 34	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	18.06	18.06	270.00	90.00	W
SURFACE 35	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.53	5.68	0.00	90.00	N
SURFACE 36	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.42	7.36	0.00	90.00	N
SURFACE 37	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	5.16	5.16	0.00	90.00	N
SURFACE 31	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	44.37	44.37	270.00	180.00	

SURFACE 38	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	44.37	44.37	270.00	0.00	
SURFACE 40	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.42	7.36	180.00	90.00	S
SURFACE 41	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.53	5.68	180.00	90.00	S
SURFACE 42	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	18.03	18.03	270.00	90.00	W
SURFACE 43	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	22.11	22.11	0.00	90.00	N
SURFACE 44	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	18.03	15.16	90.00	90.00	E
SURFACE 45	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	5.16	5.16	180.00	90.00	S
SURFACE 39	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	44.29	44.29	270.00	180.00	
SURFACE 46	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	44.29	44.29	270.00	0.00	
SURFACE 48	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.34	14.34	270.00	90.00	W
SURFACE 49	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	22.11	19.24	0.00	90.00	N
SURFACE 50	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	14.34	11.47	90.00	90.00	E
SURFACE 51	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	22.11	22.11	180.00	90.00	S
SURFACE 47	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	35.23	35.23	270.00	180.00	
SURFACE 52	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	35.23	35.23	270.00	0.00	
SURFACE 145	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	7.24	7.24	270.00	90.00	W
SURFACE 146	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	22.11	20.26	0.00	90.00	N
SURFACE 147	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	16.57	16.57	90.00	90.00	E
SURFACE 148	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	8.82	8.82	180.00	90.00	S
SURFACE 149	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	13.29	13.29	180.00	90.00	S
SURFACE 150	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	9.33	7.48	270.00	90.00	W
SURFACE 144	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	40.72	40.72	270.00	180.00	
SURFACE 151	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	40.72	40.72	270.00	0.00	
SURFACE 128	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 1	0.08	2.654	4.404	14.34	14.34	270.00	90.00	W
SURFACE 129	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	0.00	90.00	N
SURFACE 130	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	3.81	1.96	90.00	90.00	E
SURFACE 131	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	6.03	6.03	90.00	90.00	E
SURFACE 132	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	4.50	2.65	90.00	90.00	E
SURFACE 133	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	19.82	19.82	180.00	90.00	S
SURFACE 127	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	31.58	31.58	270.00	180.00	
SURFACE 134	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	31.58	31.58	270.00	0.00	
SURFACE 255	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	10.11	10.11	180.00	90.00	S
SURFACE 256	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 1	0.08	2.654	4.404	3.57	3.57	270.00	90.00	W
SURFACE 257	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	10.11	10.11	0.00	90.00	N

SURFACE 258	ASHRAE 189.1-2009 EXTWALL MASS CLIMATEZONE 5	0.08	2.654	4.404	3.57	3.57	90.00	90.00	E
SURFACE 254	EXTSLABCARPET 4IN CLIMATEZONE 1-8	0.15	2.945	5.634	4.01	4.01	270.00	180.00	
SURFACE 259	ASHRAE 189.1-2009 EXTROOF IEAD CLIMATEZONE 2-5	0.30	3.939	8.582	4.01	4.01	270.00	0.00	

Opaque Interior

	Construction	Reflectance	U-Factor with Film [W/m2-K]	U-Factor no Film [W/m2-K]	Gross Area [m2]	Net Area [m2]	Azimuth [deg]	Tilt [deg]	Cardinal Direction
None									

Exterior Fenestration

	Construction	Glass Area [m2]	Frame Area [m2]	Divider Area [m2]	Area of One Opening [m2]	Area of Multiplied Openings [m2]	Glass U-Factor [W/m2-K]	Glass SHGC	Glass Visible Transmittance	Frame Conductance [W/m2-K]	Divider Conductance [W/m2-K]	Shade Control	Parent Surface	Azimuth [deg]	T [de
Total or Average						0.00	-	-	-						
North Total or Average						0.00	-	-	-						
Non-North Total or Average						0.00	-	-	-						

Interior Fenestration

	Construction	Area of One Opening [m2]	Area of Openings [m2]	Glass U-Factor [W/m2-K]	Glass SHGC	Glass Visible Transmittance	Parent Surface
Total or Average			0.00	-	-	-	

Exterior Door

	Construction	U-Factor with Film [W/m2-K]	U-Factor no Film [W/m2-K]	Gross Area [m2]	Parent Surface
PORTA37	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 153
PORTA39	EXTERIOR DOOR	6.680	56600.000	1.64	SURFACE 181
PORTA28	EXTERIOR DOOR	6.680	56600.000	2.20	SURFACE 111
PORTA31	EXTERIOR DOOR	6.680	56600.000	1.43	SURFACE 123
PORTA30	EXTERIOR DOOR	6.680	56600.000	2.06	SURFACE 125
PORTA_HALL	EXTERIOR DOOR	6.680	56600.000	2.94	SURFACE 193
PORTA27	EXTERIOR DOOR	6.680	56600.000	1.22	SURFACE 102
PORTA25	EXTERIOR DOOR	6.680	56600.000	1.82	SURFACE 92
PORTA26	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 94
PORTA21	EXTERIOR DOOR	6.680	56600.000	1.28	SURFACE 74
PORTA43	EXTERIOR DOOR	6.680	56600.000	2.06	SURFACE 200
PORTA_HALLRECUP	EXTERIOR DOOR	6.680	56600.000	2.94	SURFACE 201
PORTA38	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 165
PORTA24	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 86
PORTA22	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 79
PORTA23	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 81
PORTA29	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 117
PORTA19	EXTERIOR DOOR	6.680	56600.000	2.06	SURFACE 54
PORTA20	EXTERIOR DOOR	6.680	56600.000	2.87	SURFACE 60
PORTA34	EXTERIOR DOOR	6.680	56600.000	1.63	SURFACE 138
PORTA9	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 2
PORTA14	EXTERIOR DOOR	6.680	56600.000	2.87	SURFACE 4
PORTA10	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 10

PORTA15	EXTERIOR DOOR	6.680	56600.000	2.87	SURFACE 8
PORTA11	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 14
PORTA16	EXTERIOR DOOR	6.680	56600.000	2.87	SURFACE 16
PORTA12	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 20
PORTA17	EXTERIOR DOOR	6.680	56600.000	2.87	SURFACE 22
PORTA18	EXTERIOR DOOR	6.680	56600.000	2.87	SURFACE 26
PORTA13	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 28
PORTA6	EXTERIOR DOOR	6.680	56600.000	2.87	SURFACE 32
PORTA2	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 35
PORTA1	EXTERIOR DOOR	6.680	56600.000	2.06	SURFACE 36
PORTA3	EXTERIOR DOOR	6.680	56600.000	2.06	SURFACE 40
PORTA4	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 41
PORTA7	EXTERIOR DOOR	6.680	56600.000	2.87	SURFACE 44
PORTA5	EXTERIOR DOOR	6.680	56600.000	2.87	SURFACE 49
PORTA8	EXTERIOR DOOR	6.680	56600.000	2.87	SURFACE 50
PORTA35	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 146
PORTA36	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 150
PORTA33	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 130
PORTA32	EXTERIOR DOOR	6.680	56600.000	1.85	SURFACE 132

Interior Door

	Construction	U-Factor with Film [W/m2-K]	U-Factor no Film [W/m2-K]	Gross Area [m2]	Parent Surface
None					

Report: **SpaceGainsMonthly**

Table of Contents

For: **CIRCENT**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	221.65	107.89	77.38	0.00	0.00	0.00	0.00	3.12	9.89
February	200.20	97.45	69.89	0.00	0.00	0.00	0.00	3.19	9.75
March	221.65	107.89	77.38	0.00	0.00	0.00	0.00	4.30	8.93
April	214.50	104.41	74.88	0.00	0.00	0.00	0.00	2.86	10.35
May	221.65	107.89	77.38	0.00	0.00	0.00	0.00	3.50	12.64
June	214.50	104.41	74.88	0.00	0.00	0.00	0.00	1.21	17.77
July	221.65	107.89	77.38	0.00	0.00	0.00	0.00	2.63	16.22
August	221.65	107.89	77.38	0.00	0.00	0.00	0.00	4.13	14.57
September	214.50	104.41	74.88	0.00	0.00	0.00	0.00	6.31	9.48
October	221.65	107.89	77.38	0.00	0.00	0.00	0.00	7.25	8.05
November	214.50	104.41	74.88	0.00	0.00	0.00	0.00	2.28	10.08
December	221.65	107.89	77.38	0.00	0.00	0.00	0.00	2.60	9.93
Annual Sum or Average	2609.81	1270.37	911.07	0.00	0.00	0.00	0.00	43.38	137.65
Minimum of Months	200.20	97.45	69.89	0.00	0.00	0.00	0.00	1.21	8.05
Maximum of Months	221.65	107.89	77.38	0.00	0.00	0.00	0.00	7.25	17.77

Report: **SpaceGainsMonthly**

Table of Contents

For: **CIRCPERIF**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	4223.91	2056.06	1474.55	0.00	0.00	0.00	0.00	147.35	23.86
February	3815.14	1857.09	1331.85	0.00	0.00	0.00	0.00	135.07	31.67
March	4223.91	2056.06	1474.55	0.00	0.00	0.00	0.00	169.96	18.18
April	4087.65	1989.74	1426.98	0.00	0.00	0.00	0.00	136.63	51.67
May	4223.91	2056.06	1474.55	0.00	0.00	0.00	0.00	135.27	94.03
June	4087.65	1989.74	1426.98	0.00	0.00	0.00	0.00	66.79	164.86
July	4223.91	2056.06	1474.55	0.00	0.00	0.00	0.00	107.34	149.33
August	4223.91	2056.06	1474.55	0.00	0.00	0.00	0.00	139.63	128.75
September	4087.65	1989.74	1426.98	0.00	0.00	0.00	0.00	195.93	51.44
October	4223.91	2056.06	1474.55	0.00	0.00	0.00	0.00	231.35	29.78
November	4087.65	1989.74	1426.98	0.00	0.00	0.00	0.00	124.33	23.55
December	4223.91	2056.06	1474.55	0.00	0.00	0.00	0.00	130.65	17.72
Annual Sum or Average	49733.11	24208.48	17361.64	0.00	0.00	0.00	0.00	1720.30	784.84
Minimum of Months	3815.14	1857.09	1331.85	0.00	0.00	0.00	0.00	66.79	17.72
Maximum of Months	4223.91	2056.06	1474.55	0.00	0.00	0.00	0.00	231.35	164.86

Report: **SpaceGainsMonthly**

Table of Contents

For: **DEPOSITO**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	173.50	84.45	60.57	0.00	0.00	0.00	0.00	0.43	14.68
February	156.71	76.28	54.71	0.00	0.00	0.00	0.00	0.61	14.04
March	173.50	84.45	60.57	0.00	0.00	0.00	0.00	1.25	13.30
April	167.90	81.73	58.61	0.00	0.00	0.00	0.00	1.00	13.23
May	173.50	84.45	60.57	0.00	0.00	0.00	0.00	2.40	14.23
June	167.90	81.73	58.61	0.00	0.00	0.00	0.00	2.40	14.56
July	173.50	84.45	60.57	0.00	0.00	0.00	0.00	3.55	14.30
August	173.50	84.45	60.57	0.00	0.00	0.00	0.00	4.00	14.35
September	167.90	81.73	58.61	0.00	0.00	0.00	0.00	3.05	12.67
October	173.50	84.45	60.57	0.00	0.00	0.00	0.00	2.22	13.04
November	167.90	81.73	58.61	0.00	0.00	0.00	0.00	0.35	14.32
December	173.50	84.45	60.57	0.00	0.00	0.00	0.00	0.50	13.90
Annual Sum or Average	2042.82	994.38	713.14	0.00	0.00	0.00	0.00	21.75	166.62
Minimum of Months	156.71	76.28	54.71	0.00	0.00	0.00	0.00	0.35	12.67

Maximum of Months	173.50	84.45	60.57	0.00	0.00	0.00	0.00	4.00	14.68

Report: **SpaceGainsMonthly**

Table of Contents

For: **ESTARPESSOAL**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	97.52	47.47	34.04	0.00	0.00	0.00	0.00	1.66	4.94
February	88.08	42.87	30.75	0.00	0.00	0.00	0.00	1.71	4.87
March	97.52	47.47	34.04	0.00	0.00	0.00	0.00	2.30	4.45
April	94.37	45.94	32.94	0.00	0.00	0.00	0.00	1.57	5.15
May	97.52	47.47	34.04	0.00	0.00	0.00	0.00	1.96	6.35
June	94.37	45.94	32.94	0.00	0.00	0.00	0.00	0.83	9.07
July	97.52	47.47	34.04	0.00	0.00	0.00	0.00	1.59	8.32
August	97.52	47.47	34.04	0.00	0.00	0.00	0.00	2.35	7.44
September	94.37	45.94	32.94	0.00	0.00	0.00	0.00	3.40	4.74
October	97.52	47.47	34.04	0.00	0.00	0.00	0.00	3.88	4.04
November	94.37	45.94	32.94	0.00	0.00	0.00	0.00	1.22	5.04
December	97.52	47.47	34.04	0.00	0.00	0.00	0.00	1.39	4.94
Annual Sum or Average	1148.18	558.90	400.82	0.00	0.00	0.00	0.00	23.86	69.35
Minimum of Months	88.08	42.87	30.75	0.00	0.00	0.00	0.00	0.83	4.04
Maximum of Months	97.52	47.47	34.04	0.00	0.00	0.00	0.00	3.88	9.07

Report: **SpaceGainsMonthly**

Table of Contents

For: **EXPURGO**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	199.06	96.90	69.49	0.00	0.00	0.00	0.00	0.11	16.43
February	179.80	87.52	62.77	0.00	0.00	0.00	0.00	0.16	15.50
March	199.06	96.90	69.49	0.00	0.00	0.00	0.00	0.49	14.53
April	192.64	93.77	67.25	0.00	0.00	0.00	0.00	0.23	14.47
May	199.06	96.90	69.49	0.00	0.00	0.00	0.00	1.15	15.10
June	192.64	93.77	67.25	0.00	0.00	0.00	0.00	1.05	15.64
July	199.06	96.90	69.49	0.00	0.00	0.00	0.00	1.90	15.10
August	199.06	96.90	69.49	0.00	0.00	0.00	0.00	2.31	15.06
September	192.64	93.77	67.25	0.00	0.00	0.00	0.00	1.78	13.42
October	199.06	96.90	69.49	0.00	0.00	0.00	0.00	1.09	13.91
November	192.64	93.77	67.25	0.00	0.00	0.00	0.00	0.06	15.91
December	199.06	96.90	69.49	0.00	0.00	0.00	0.00	0.13	15.47

Annual Sum or Average	2343.79	1140.88	818.21	0.00	0.00	0.00	0.00	10.47	180.56
Minimum of Months	179.80	87.52	62.77	0.00	0.00	0.00	0.00	0.06	13.42
Maximum of Months	199.06	96.90	69.49	0.00	0.00	0.00	0.00	2.31	16.43

Report: **SpaceGainsMonthly** Table of Contents

For: **HALL**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	657.64	320.12	229.58	0.00	0.00	0.00	0.00	7.44	24.84
February	594.00	289.14	207.36	0.00	0.00	0.00	0.00	7.59	24.46
March	657.64	320.12	229.58	0.00	0.00	0.00	0.00	10.27	22.48
April	636.42	309.79	222.17	0.00	0.00	0.00	0.00	6.74	26.30
May	657.64	320.12	229.58	0.00	0.00	0.00	0.00	7.95	31.79
June	636.42	309.79	222.17	0.00	0.00	0.00	0.00	1.97	44.43
July	657.64	320.12	229.58	0.00	0.00	0.00	0.00	5.36	40.16
August	657.64	320.12	229.58	0.00	0.00	0.00	0.00	9.05	36.06
September	636.42	309.79	222.17	0.00	0.00	0.00	0.00	14.91	23.87
October	657.64	320.12	229.58	0.00	0.00	0.00	0.00	17.24	20.13
November	636.42	309.79	222.17	0.00	0.00	0.00	0.00	5.43	25.34
December	657.64	320.12	229.58	0.00	0.00	0.00	0.00	6.18	25.07
Annual Sum or Average	7743.17	3769.13	2703.11	0.00	0.00	0.00	0.00	100.14	344.93
Minimum of Months	594.00	289.14	207.36	0.00	0.00	0.00	0.00	1.97	20.13
Maximum of Months	657.64	320.12	229.58	0.00	0.00	0.00	0.00	17.24	44.43

Report: **SpaceGainsMonthly** Table of Contents

For: **HOMVESTAUX**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	199.06	96.90	69.49	0.00	0.00	0.00	0.00	0.11	16.26
February	179.80	87.52	62.77	0.00	0.00	0.00	0.00	0.17	15.36
March	199.06	96.90	69.49	0.00	0.00	0.00	0.00	0.51	14.42
April	192.64	93.77	67.25	0.00	0.00	0.00	0.00	0.25	14.38
May	199.06	96.90	69.49	0.00	0.00	0.00	0.00	1.17	15.04
June	192.64	93.77	67.25	0.00	0.00	0.00	0.00	1.07	15.60
July	199.06	96.90	69.49	0.00	0.00	0.00	0.00	1.92	15.09
August	199.06	96.90	69.49	0.00	0.00	0.00	0.00	2.33	15.05
September	192.64	93.77	67.25	0.00	0.00	0.00	0.00	1.79	13.39

October	199.06	96.90	69.49	0.00	0.00	0.00	0.00	1.11	13.86
November	192.64	93.77	67.25	0.00	0.00	0.00	0.00	0.07	15.74
December	199.06	96.90	69.49	0.00	0.00	0.00	0.00	0.13	15.30
Annual Sum or Average	2343.79	1140.88	818.21	0.00	0.00	0.00	0.00	10.63	179.48
Minimum of Months	179.80	87.52	62.77	0.00	0.00	0.00	0.00	0.07	13.39
Maximum of Months	199.06	96.90	69.49	0.00	0.00	0.00	0.00	2.33	16.26

Report: **SpaceGainsMonthly** Table of Contents

For: **MATANEST**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	208.51	101.49	72.79	0.00	0.00	0.00	0.00	4.48	7.91
February	188.33	91.67	65.74	0.00	0.00	0.00	0.00	4.49	8.06
March	208.51	101.49	72.79	0.00	0.00	0.00	0.00	5.77	7.07
April	201.78	98.22	70.44	0.00	0.00	0.00	0.00	4.24	8.87
May	208.51	101.49	72.79	0.00	0.00	0.00	0.00	4.78	11.07
June	201.78	98.22	70.44	0.00	0.00	0.00	0.00	2.02	13.86
July	208.51	101.49	72.79	0.00	0.00	0.00	0.00	3.75	13.01
August	208.51	101.49	72.79	0.00	0.00	0.00	0.00	5.40	12.13
September	201.78	98.22	70.44	0.00	0.00	0.00	0.00	7.90	8.15
October	208.51	101.49	72.79	0.00	0.00	0.00	0.00	9.19	6.53
November	201.78	98.22	70.44	0.00	0.00	0.00	0.00	3.50	8.17
December	208.51	101.49	72.79	0.00	0.00	0.00	0.00	3.74	7.85
Annual Sum or Average	2455.00	1195.01	857.03	0.00	0.00	0.00	0.00	59.25	112.69
Minimum of Months	188.33	91.67	65.74	0.00	0.00	0.00	0.00	2.02	6.53
Maximum of Months	208.51	101.49	72.79	0.00	0.00	0.00	0.00	9.19	13.86

Report: **SpaceGainsMonthly** Table of Contents

For: **POSTOENF**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	220.22	107.20	76.88	0.00	0.00	0.00	0.00	5.00	5.49
February	198.91	96.82	69.44	0.00	0.00	0.00	0.00	4.93	5.60
March	220.22	107.20	76.88	0.00	0.00	0.00	0.00	6.27	4.82
April	213.12	103.74	74.40	0.00	0.00	0.00	0.00	4.73	5.90
May	220.22	107.20	76.88	0.00	0.00	0.00	0.00	5.12	7.16

June	213.12	103.74	74.40	0.00	0.00	0.00	0.00	1.94	8.94
July	220.22	107.20	76.88	0.00	0.00	0.00	0.00	3.77	8.36
August	220.22	107.20	76.88	0.00	0.00	0.00	0.00	5.49	7.75
September	213.12	103.74	74.40	0.00	0.00	0.00	0.00	8.31	5.33
October	220.22	107.20	76.88	0.00	0.00	0.00	0.00	9.69	4.40
November	213.12	103.74	74.40	0.00	0.00	0.00	0.00	3.98	5.65
December	220.22	107.20	76.88	0.00	0.00	0.00	0.00	4.19	5.42
Annual Sum or Average	2592.94	1262.16	905.19	0.00	0.00	0.00	0.00	63.44	74.83
Minimum of Months	198.91	96.82	69.44	0.00	0.00	0.00	0.00	1.94	4.40
Maximum of Months	220.22	107.20	76.88	0.00	0.00	0.00	0.00	9.69	8.94

Report: **SpaceGainsMonthly**

Table of Contents

For: **RECUPPOSANEST**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	1438.10	700.02	502.04	0.00	0.00	0.00	0.00	16.64	22.66
February	1298.93	632.28	453.45	0.00	0.00	0.00	0.00	16.41	23.77
March	1438.10	700.02	502.04	0.00	0.00	0.00	0.00	20.87	20.23
April	1391.71	677.44	485.84	0.00	0.00	0.00	0.00	15.74	28.98
May	1438.10	700.02	502.04	0.00	0.00	0.00	0.00	16.90	39.40
June	1391.71	677.44	485.84	0.00	0.00	0.00	0.00	5.64	56.28
July	1438.10	700.02	502.04	0.00	0.00	0.00	0.00	11.86	50.59
August	1438.10	700.02	502.04	0.00	0.00	0.00	0.00	17.71	45.22
September	1391.71	677.44	485.84	0.00	0.00	0.00	0.00	27.63	26.77
October	1438.10	700.02	502.04	0.00	0.00	0.00	0.00	32.26	19.77
November	1391.71	677.44	485.84	0.00	0.00	0.00	0.00	13.26	23.60
December	1438.10	700.02	502.04	0.00	0.00	0.00	0.00	13.96	22.41
Annual Sum or Average	16932.52	8242.21	5911.08	0.00	0.00	0.00	0.00	208.89	379.66
Minimum of Months	1298.93	632.28	453.45	0.00	0.00	0.00	0.00	5.64	19.77
Maximum of Months	1438.10	700.02	502.04	0.00	0.00	0.00	0.00	32.26	56.28

Report: **SpaceGainsMonthly**

Table of Contents

For: **REPFEM**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	270.86	131.85	94.56	0.00	0.00	0.00	0.00	3.00	10.03

February	244.65	119.09	85.41	0.00	0.00	0.00	0.00	3.06	9.86
March	270.86	131.85	94.56	0.00	0.00	0.00	0.00	4.14	9.07
April	262.13	127.59	91.51	0.00	0.00	0.00	0.00	2.72	10.61
May	270.86	131.85	94.56	0.00	0.00	0.00	0.00	3.19	12.83
June	262.13	127.59	91.51	0.00	0.00	0.00	0.00	0.74	17.99
July	270.86	131.85	94.56	0.00	0.00	0.00	0.00	2.10	16.22
August	270.86	131.85	94.56	0.00	0.00	0.00	0.00	3.60	14.55
September	262.13	127.59	91.51	0.00	0.00	0.00	0.00	6.00	9.62
October	270.86	131.85	94.56	0.00	0.00	0.00	0.00	6.95	8.11
November	262.13	127.59	91.51	0.00	0.00	0.00	0.00	2.19	10.23
December	270.86	131.85	94.56	0.00	0.00	0.00	0.00	2.49	10.13
Annual Sum or Average	3189.19	1552.40	1113.33	0.00	0.00	0.00	0.00	40.18	139.25
Minimum of Months	244.65	119.09	85.41	0.00	0.00	0.00	0.00	0.74	8.11
Maximum of Months	270.86	131.85	94.56	0.00	0.00	0.00	0.00	6.95	17.99

Report: **SpaceGainsMonthly**

Table of Contents

For: **REPMASC**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	223.00	108.55	77.85	0.00	0.00	0.00	0.00	2.90	9.40
February	201.42	98.04	70.31	0.00	0.00	0.00	0.00	2.96	9.28
March	223.00	108.55	77.85	0.00	0.00	0.00	0.00	3.99	8.51
April	215.80	105.05	75.34	0.00	0.00	0.00	0.00	2.64	9.90
May	223.00	108.55	77.85	0.00	0.00	0.00	0.00	3.20	12.04
June	215.80	105.05	75.34	0.00	0.00	0.00	0.00	1.03	16.81
July	223.00	108.55	77.85	0.00	0.00	0.00	0.00	2.35	15.33
August	223.00	108.55	77.85	0.00	0.00	0.00	0.00	3.75	13.79
September	215.80	105.05	75.34	0.00	0.00	0.00	0.00	5.84	9.06
October	223.00	108.55	77.85	0.00	0.00	0.00	0.00	6.72	7.66
November	215.80	105.05	75.34	0.00	0.00	0.00	0.00	2.12	9.58
December	223.00	108.55	77.85	0.00	0.00	0.00	0.00	2.41	9.45
Annual Sum or Average	2625.62	1278.07	916.60	0.00	0.00	0.00	0.00	39.90	130.82
Minimum of Months	201.42	98.04	70.31	0.00	0.00	0.00	0.00	1.03	7.66
Maximum of Months	223.00	108.55	77.85	0.00	0.00	0.00	0.00	6.72	16.81

Report: **SpaceGainsMonthly**

Table of Contents

For: **ROUPASUJA**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE	ZONE	ZONE	ZONE GAS	ZONE HOT	ZONE	ZONE	ZONE	ZONE

	PEOPLE TOTAL HEATING ENERGY [kWh]	LIGHTS TOTAL HEATING ENERGY [kWh]	ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	EQUIPMENT TOTAL HEATING ENERGY []	WATER EQUIPMENT TOTAL HEATING ENERGY []	STEAM EQUIPMENT TOTAL HEATING ENERGY []	OTHER EQUIPMENT TOTAL HEATING ENERGY []	INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	197.40	96.09	68.91	0.00	0.00	0.00	0.00	0.11	16.32
February	178.30	86.79	62.24	0.00	0.00	0.00	0.00	0.17	15.40
March	197.40	96.09	68.91	0.00	0.00	0.00	0.00	0.50	14.44
April	191.03	92.99	66.69	0.00	0.00	0.00	0.00	0.24	14.37
May	197.40	96.09	68.91	0.00	0.00	0.00	0.00	1.16	15.00
June	191.03	92.99	66.69	0.00	0.00	0.00	0.00	1.07	15.53
July	197.40	96.09	68.91	0.00	0.00	0.00	0.00	1.92	15.00
August	197.40	96.09	68.91	0.00	0.00	0.00	0.00	2.33	14.96
September	191.03	92.99	66.69	0.00	0.00	0.00	0.00	1.79	13.33
October	197.40	96.09	68.91	0.00	0.00	0.00	0.00	1.10	13.82
November	191.03	92.99	66.69	0.00	0.00	0.00	0.00	0.07	15.81
December	197.40	96.09	68.91	0.00	0.00	0.00	0.00	0.13	15.37
Annual Sum or Average	2324.26	1131.37	811.39	0.00	0.00	0.00	0.00	10.57	179.36
Minimum of Months	178.30	86.79	62.24	0.00	0.00	0.00	0.00	0.07	13.33
Maximum of Months	197.40	96.09	68.91	0.00	0.00	0.00	0.00	2.33	16.32

Report: **SpaceGainsMonthly**

Table of Contents

For: **ROUPARIA**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	95.89	46.68	33.48	0.00	0.00	0.00	0.00	0.19	8.14
February	86.61	42.16	30.24	0.00	0.00	0.00	0.00	0.27	7.75
March	95.89	46.68	33.48	0.00	0.00	0.00	0.00	0.59	7.32
April	92.80	45.17	32.40	0.00	0.00	0.00	0.00	0.45	7.26
May	95.89	46.68	33.48	0.00	0.00	0.00	0.00	1.17	7.77
June	92.80	45.17	32.40	0.00	0.00	0.00	0.00	1.16	7.96
July	95.89	46.68	33.48	0.00	0.00	0.00	0.00	1.76	7.78
August	95.89	46.68	33.48	0.00	0.00	0.00	0.00	2.00	7.80
September	92.80	45.17	32.40	0.00	0.00	0.00	0.00	1.53	6.91
October	95.89	46.68	33.48	0.00	0.00	0.00	0.00	1.09	7.12
November	92.80	45.17	32.40	0.00	0.00	0.00	0.00	0.15	7.92
December	95.89	46.68	33.48	0.00	0.00	0.00	0.00	0.22	7.70
Annual Sum or Average	1129.04	549.58	394.14	0.00	0.00	0.00	0.00	10.59	91.43
Minimum of Months	86.61	42.16	30.24	0.00	0.00	0.00	0.00	0.15	6.91
Maximum of Months	95.89	46.68	33.48	0.00	0.00	0.00	0.00	2.00	8.14

Report: **SpaceGainsMonthly**

Table of Contents

For: **SOP1**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	406.42	197.83	141.88	0.00	0.00	0.00	0.00	14.10	2.28
February	367.09	178.69	128.15	0.00	0.00	0.00	0.00	12.92	3.03
March	406.42	197.83	141.88	0.00	0.00	0.00	0.00	16.26	1.74
April	393.31	191.45	137.30	0.00	0.00	0.00	0.00	13.07	4.85
May	406.42	197.83	141.88	0.00	0.00	0.00	0.00	12.94	8.62
June	393.31	191.45	137.30	0.00	0.00	0.00	0.00	6.39	14.45
July	406.42	197.83	141.88	0.00	0.00	0.00	0.00	10.27	13.03
August	406.42	197.83	141.88	0.00	0.00	0.00	0.00	13.36	11.36
September	393.31	191.45	137.30	0.00	0.00	0.00	0.00	18.74	4.81
October	406.42	197.83	141.88	0.00	0.00	0.00	0.00	22.13	2.83
November	393.31	191.45	137.30	0.00	0.00	0.00	0.00	11.89	2.25
December	406.42	197.83	141.88	0.00	0.00	0.00	0.00	12.50	1.69
Annual Sum or Average	4785.23	2329.30	1670.51	0.00	0.00	0.00	0.00	164.55	70.93
Minimum of Months	367.09	178.69	128.15	0.00	0.00	0.00	0.00	6.39	1.69
Maximum of Months	406.42	197.83	141.88	0.00	0.00	0.00	0.00	22.13	14.45

Report: **SpaceGainsMonthly**

Table of Contents

For: **SOP2**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	397.87	193.67	138.89	0.00	0.00	0.00	0.00	13.92	2.25
February	359.37	174.93	125.45	0.00	0.00	0.00	0.00	12.76	2.99
March	397.87	193.67	138.89	0.00	0.00	0.00	0.00	16.06	1.72
April	385.03	187.42	134.41	0.00	0.00	0.00	0.00	12.91	4.78
May	397.87	193.67	138.89	0.00	0.00	0.00	0.00	12.78	8.48
June	385.03	187.42	134.41	0.00	0.00	0.00	0.00	6.31	14.19
July	397.87	193.67	138.89	0.00	0.00	0.00	0.00	10.14	12.79
August	397.87	193.67	138.89	0.00	0.00	0.00	0.00	13.19	11.16
September	385.03	187.42	134.41	0.00	0.00	0.00	0.00	18.51	4.74
October	397.87	193.67	138.89	0.00	0.00	0.00	0.00	21.86	2.79
November	385.03	187.42	134.41	0.00	0.00	0.00	0.00	11.75	2.22
December	397.87	193.67	138.89	0.00	0.00	0.00	0.00	12.35	1.67
Annual Sum or Average	4684.59	2280.31	1635.37	0.00	0.00	0.00	0.00	162.54	69.79
Minimum of Months	359.37	174.93	125.45	0.00	0.00	0.00	0.00	6.31	1.67
Maximum	397.87	193.67	138.89	0.00	0.00	0.00	0.00	21.86	14.19

of Months									

Report: **SpaceGainsMonthly**

Table of Contents

For: **SOP3**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	392.32	190.97	136.96	0.00	0.00	0.00	0.00	13.81	2.24
February	354.35	172.49	123.70	0.00	0.00	0.00	0.00	12.66	2.97
March	392.32	190.97	136.96	0.00	0.00	0.00	0.00	15.93	1.70
April	379.66	184.81	132.54	0.00	0.00	0.00	0.00	12.81	4.78
May	392.32	190.97	136.96	0.00	0.00	0.00	0.00	12.68	8.54
June	379.66	184.81	132.54	0.00	0.00	0.00	0.00	6.26	14.45
July	392.32	190.97	136.96	0.00	0.00	0.00	0.00	10.06	13.05
August	392.32	190.97	136.96	0.00	0.00	0.00	0.00	13.09	11.36
September	379.66	184.81	132.54	0.00	0.00	0.00	0.00	18.36	4.74
October	392.32	190.97	136.96	0.00	0.00	0.00	0.00	21.68	2.78
November	379.66	184.81	132.54	0.00	0.00	0.00	0.00	11.65	2.21
December	392.32	190.97	136.96	0.00	0.00	0.00	0.00	12.25	1.66
Annual Sum or Average	4619.21	2248.49	1612.55	0.00	0.00	0.00	0.00	161.23	70.47
Minimum of Months	354.35	172.49	123.70	0.00	0.00	0.00	0.00	6.26	1.66
Maximum of Months	392.32	190.97	136.96	0.00	0.00	0.00	0.00	21.68	14.45

Report: **SpaceGainsMonthly**

Table of Contents

For: **SOP4**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	396.72	193.11	138.49	0.00	0.00	0.00	0.00	13.90	2.25
February	358.33	174.42	125.09	0.00	0.00	0.00	0.00	12.74	2.99
March	396.72	193.11	138.49	0.00	0.00	0.00	0.00	16.03	1.71
April	383.92	186.88	134.02	0.00	0.00	0.00	0.00	12.89	4.77
May	396.72	193.11	138.49	0.00	0.00	0.00	0.00	12.76	8.47
June	383.92	186.88	134.02	0.00	0.00	0.00	0.00	6.30	14.15
July	396.72	193.11	138.49	0.00	0.00	0.00	0.00	10.12	12.76
August	396.72	193.11	138.49	0.00	0.00	0.00	0.00	13.17	11.13
September	383.92	186.88	134.02	0.00	0.00	0.00	0.00	18.48	4.73
October	396.72	193.11	138.49	0.00	0.00	0.00	0.00	21.82	2.78
November	383.92	186.88	134.02	0.00	0.00	0.00	0.00	11.73	2.22
December	396.72	193.11	138.49	0.00	0.00	0.00	0.00	12.32	1.67

Annual Sum or Average	4671.02	2273.71	1630.64	0.00	0.00	0.00	0.00	162.27	69.64
Minimum of Months	358.33	174.42	125.09	0.00	0.00	0.00	0.00	6.30	1.67
Maximum of Months	396.72	193.11	138.49	0.00	0.00	0.00	0.00	21.82	14.15

Report: **SpaceGainsMonthly** Table of Contents

For: **SOP5**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	398.95	194.20	139.27	0.00	0.00	0.00	0.00	13.94	2.26
February	360.34	175.40	125.79	0.00	0.00	0.00	0.00	12.78	3.00
March	398.95	194.20	139.27	0.00	0.00	0.00	0.00	16.08	1.72
April	386.08	187.93	134.78	0.00	0.00	0.00	0.00	12.93	4.79
May	398.95	194.20	139.27	0.00	0.00	0.00	0.00	12.80	8.50
June	386.08	187.93	134.78	0.00	0.00	0.00	0.00	6.32	14.22
July	398.95	194.20	139.27	0.00	0.00	0.00	0.00	10.16	12.82
August	398.95	194.20	139.27	0.00	0.00	0.00	0.00	13.21	11.19
September	386.08	187.93	134.78	0.00	0.00	0.00	0.00	18.54	4.75
October	398.95	194.20	139.27	0.00	0.00	0.00	0.00	21.89	2.79
November	386.08	187.93	134.78	0.00	0.00	0.00	0.00	11.77	2.23
December	398.95	194.20	139.27	0.00	0.00	0.00	0.00	12.36	1.68
Annual Sum or Average	4697.34	2286.51	1639.82	0.00	0.00	0.00	0.00	162.80	69.94
Minimum of Months	360.34	175.40	125.79	0.00	0.00	0.00	0.00	6.32	1.68
Maximum of Months	398.95	194.20	139.27	0.00	0.00	0.00	0.00	21.89	14.22

Report: **SpaceGainsMonthly** Table of Contents

For: **SOP6**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	557.03	271.15	194.46	0.00	0.00	0.00	0.00	17.46	2.83
February	503.13	244.91	175.64	0.00	0.00	0.00	0.00	16.01	3.75
March	557.03	271.15	194.46	0.00	0.00	0.00	0.00	20.14	2.15
April	539.06	262.40	188.19	0.00	0.00	0.00	0.00	16.19	6.02
May	557.03	271.15	194.46	0.00	0.00	0.00	0.00	16.03	10.73
June	539.06	262.40	188.19	0.00	0.00	0.00	0.00	7.91	18.08
July	557.03	271.15	194.46	0.00	0.00	0.00	0.00	12.72	16.27
August	557.03	271.15	194.46	0.00	0.00	0.00	0.00	16.55	14.16
September	539.06	262.40	188.19	0.00	0.00	0.00	0.00	23.22	5.97

October	557.03	271.15	194.46	0.00	0.00	0.00	0.00	27.42	3.51
November	539.06	262.40	188.19	0.00	0.00	0.00	0.00	14.74	2.79
December	557.03	271.15	194.46	0.00	0.00	0.00	0.00	15.48	2.10
Annual Sum or Average	6558.61	3192.52	2289.59	0.00	0.00	0.00	0.00	203.86	88.36
Minimum of Months	503.13	244.91	175.64	0.00	0.00	0.00	0.00	7.91	2.10
Maximum of Months	557.03	271.15	194.46	0.00	0.00	0.00	0.00	27.42	18.08

Report: **SpaceGainsMonthly** Table of Contents

For: **SOP7**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	556.11	270.70	194.13	0.00	0.00	0.00	0.00	17.44	2.82
February	502.29	244.50	175.35	0.00	0.00	0.00	0.00	15.99	3.75
March	556.11	270.70	194.13	0.00	0.00	0.00	0.00	20.12	2.15
April	538.17	261.96	187.87	0.00	0.00	0.00	0.00	16.18	6.01
May	556.11	270.70	194.13	0.00	0.00	0.00	0.00	16.01	10.71
June	538.17	261.96	187.87	0.00	0.00	0.00	0.00	7.90	18.06
July	556.11	270.70	194.13	0.00	0.00	0.00	0.00	12.70	16.24
August	556.11	270.70	194.13	0.00	0.00	0.00	0.00	16.53	14.14
September	538.17	261.96	187.87	0.00	0.00	0.00	0.00	23.20	5.96
October	556.11	270.70	194.13	0.00	0.00	0.00	0.00	27.39	3.50
November	538.17	261.96	187.87	0.00	0.00	0.00	0.00	14.72	2.79
December	556.11	270.70	194.13	0.00	0.00	0.00	0.00	15.47	2.10
Annual Sum or Average	6547.72	3187.22	2285.78	0.00	0.00	0.00	0.00	203.65	88.24
Minimum of Months	502.29	244.50	175.35	0.00	0.00	0.00	0.00	7.90	2.10
Maximum of Months	556.11	270.70	194.13	0.00	0.00	0.00	0.00	27.39	18.06

Report: **SpaceGainsMonthly** Table of Contents

For: **SOP8**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	442.30	215.30	154.40	0.00	0.00	0.00	0.00	15.12	2.45
February	399.49	194.46	139.46	0.00	0.00	0.00	0.00	13.86	3.25
March	442.30	215.30	154.40	0.00	0.00	0.00	0.00	17.44	1.87
April	428.03	208.35	149.42	0.00	0.00	0.00	0.00	14.02	5.18
May	442.30	215.30	154.40	0.00	0.00	0.00	0.00	13.88	9.18

June	428.03	208.35	149.42	0.00	0.00	0.00	0.00	6.85	15.31
July	442.30	215.30	154.40	0.00	0.00	0.00	0.00	11.01	13.78
August	442.30	215.30	154.40	0.00	0.00	0.00	0.00	14.33	12.03
September	428.03	208.35	149.42	0.00	0.00	0.00	0.00	20.11	5.13
October	442.30	215.30	154.40	0.00	0.00	0.00	0.00	23.75	3.03
November	428.03	208.35	149.42	0.00	0.00	0.00	0.00	12.76	2.42
December	442.30	215.30	154.40	0.00	0.00	0.00	0.00	13.41	1.82
Annual Sum or Average	5207.67	2534.93	1817.98	0.00	0.00	0.00	0.00	176.56	75.44
Minimum of Months	399.49	194.46	139.46	0.00	0.00	0.00	0.00	6.85	1.82
Maximum of Months	442.30	215.30	154.40	0.00	0.00	0.00	0.00	23.75	15.31

Report: **SpaceGainsMonthly**

Table of Contents

For: **SALA**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	102.39	49.84	35.74	0.00	0.00	0.00	0.00	2.88	3.64
February	92.48	45.02	32.29	0.00	0.00	0.00	0.00	2.85	3.78
March	102.39	49.84	35.74	0.00	0.00	0.00	0.00	3.61	3.22
April	99.09	48.23	34.59	0.00	0.00	0.00	0.00	2.74	4.22
May	102.39	49.84	35.74	0.00	0.00	0.00	0.00	3.02	5.41
June	99.09	48.23	34.59	0.00	0.00	0.00	0.00	1.40	6.86
July	102.39	49.84	35.74	0.00	0.00	0.00	0.00	2.42	6.45
August	102.39	49.84	35.74	0.00	0.00	0.00	0.00	3.36	6.00
September	99.09	48.23	34.59	0.00	0.00	0.00	0.00	4.81	3.91
October	102.39	49.84	35.74	0.00	0.00	0.00	0.00	5.59	3.04
November	99.09	48.23	34.59	0.00	0.00	0.00	0.00	2.30	3.77
December	102.39	49.84	35.74	0.00	0.00	0.00	0.00	2.42	3.56
Annual Sum or Average	1205.59	586.84	420.87	0.00	0.00	0.00	0.00	37.40	53.86
Minimum of Months	92.48	45.02	32.29	0.00	0.00	0.00	0.00	1.40	3.04
Maximum of Months	102.39	49.84	35.74	0.00	0.00	0.00	0.00	5.59	6.86

Report: **SpaceGainsMonthly**

Table of Contents

For: **SALAAUXILIAR**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	188.83	91.92	65.92	0.00	0.00	0.00	0.00	4.18	5.50

February	170.56	83.02	59.54	0.00	0.00	0.00	0.00	4.13	5.70
March	188.83	91.92	65.92	0.00	0.00	0.00	0.00	5.24	4.86
April	182.74	88.95	63.79	0.00	0.00	0.00	0.00	3.95	6.49
May	188.83	91.92	65.92	0.00	0.00	0.00	0.00	4.29	8.41
June	182.74	88.95	63.79	0.00	0.00	0.00	0.00	1.66	10.98
July	188.83	91.92	65.92	0.00	0.00	0.00	0.00	3.22	10.15
August	188.83	91.92	65.92	0.00	0.00	0.00	0.00	4.65	9.34
September	182.74	88.95	63.79	0.00	0.00	0.00	0.00	6.95	5.99
October	188.83	91.92	65.92	0.00	0.00	0.00	0.00	8.11	4.59
November	182.74	88.95	63.79	0.00	0.00	0.00	0.00	3.33	5.69
December	188.83	91.92	65.92	0.00	0.00	0.00	0.00	3.51	5.38
Annual Sum or Average	2223.38	1082.27	776.17	0.00	0.00	0.00	0.00	53.23	83.08
Minimum of Months	170.56	83.02	59.54	0.00	0.00	0.00	0.00	1.66	4.59
Maximum of Months	188.83	91.92	65.92	0.00	0.00	0.00	0.00	8.11	10.98

Report: **SpaceGainsMonthly**

Table of Contents

For: **SALAGESSO**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	439.52	213.94	153.43	0.00	0.00	0.00	0.00	7.15	9.73
February	396.99	193.24	138.59	0.00	0.00	0.00	0.00	7.05	10.15
March	439.52	213.94	153.43	0.00	0.00	0.00	0.00	8.97	8.64
April	425.34	207.04	148.48	0.00	0.00	0.00	0.00	6.76	12.13
May	439.52	213.94	153.43	0.00	0.00	0.00	0.00	7.26	16.22
June	425.34	207.04	148.48	0.00	0.00	0.00	0.00	2.48	22.50
July	439.52	213.94	153.43	0.00	0.00	0.00	0.00	5.17	20.39
August	439.52	213.94	153.43	0.00	0.00	0.00	0.00	7.69	18.42
September	425.34	207.04	148.48	0.00	0.00	0.00	0.00	11.88	11.20
October	439.52	213.94	153.43	0.00	0.00	0.00	0.00	13.86	8.34
November	425.34	207.04	148.48	0.00	0.00	0.00	0.00	5.70	10.05
December	439.52	213.94	153.43	0.00	0.00	0.00	0.00	6.00	9.56
Annual Sum or Average	5174.98	2519.02	1806.57	0.00	0.00	0.00	0.00	89.96	157.34
Minimum of Months	396.99	193.24	138.59	0.00	0.00	0.00	0.00	2.48	8.34
Maximum of Months	439.52	213.94	153.43	0.00	0.00	0.00	0.00	13.86	22.50

Report: **SpaceGainsMonthly**

Table of Contents

For: **SECCONTROLE**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE	ZONE	ZONE	ZONE GAS	ZONE HOT	ZONE	ZONE	ZONE	ZONE

	PEOPLE TOTAL HEATING ENERGY [kWh]	LIGHTS TOTAL HEATING ENERGY [kWh]	ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	EQUIPMENT TOTAL HEATING ENERGY []	WATER EQUIPMENT TOTAL HEATING ENERGY []	STEAM EQUIPMENT TOTAL HEATING ENERGY []	OTHER EQUIPMENT TOTAL HEATING ENERGY []	INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	122.07	59.42	42.61	0.00	0.00	0.00	0.00	2.03	6.12
February	110.26	53.67	38.49	0.00	0.00	0.00	0.00	2.09	6.04
March	122.07	59.42	42.61	0.00	0.00	0.00	0.00	2.80	5.52
April	118.13	57.50	41.24	0.00	0.00	0.00	0.00	1.92	6.39
May	122.07	59.42	42.61	0.00	0.00	0.00	0.00	2.40	7.87
June	118.13	57.50	41.24	0.00	0.00	0.00	0.00	1.04	11.14
July	122.07	59.42	42.61	0.00	0.00	0.00	0.00	1.97	10.24
August	122.07	59.42	42.61	0.00	0.00	0.00	0.00	2.89	9.18
September	118.13	57.50	41.24	0.00	0.00	0.00	0.00	4.15	5.89
October	122.07	59.42	42.61	0.00	0.00	0.00	0.00	4.74	5.03
November	118.13	57.50	41.24	0.00	0.00	0.00	0.00	1.49	6.24
December	122.07	59.42	42.61	0.00	0.00	0.00	0.00	1.70	6.11
Annual Sum or Average	1437.29	699.63	501.75	0.00	0.00	0.00	0.00	29.22	85.77
Minimum of Months	110.26	53.67	38.49	0.00	0.00	0.00	0.00	1.04	5.03
Maximum of Months	122.07	59.42	42.61	0.00	0.00	0.00	0.00	4.74	11.14

Report: **SpaceGainsMonthly** Table of Contents

For: **VESTFEM**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	511.18	248.83	178.45	0.00	0.00	0.00	0.00	0.00	37.89
February	461.71	224.75	161.18	0.00	0.00	0.00	0.00	0.03	35.66
March	511.18	248.83	178.45	0.00	0.00	0.00	0.00	0.03	33.46
April	494.69	240.80	172.70	0.00	0.00	0.00	0.00	0.01	33.99
May	511.18	248.83	178.45	0.00	0.00	0.00	0.00	0.18	34.08
June	494.69	240.80	172.70	0.00	0.00	0.00	0.00	0.10	36.31
July	511.18	248.83	178.45	0.00	0.00	0.00	0.00	0.52	34.11
August	511.18	248.83	178.45	0.00	0.00	0.00	0.00	0.95	33.46
September	494.69	240.80	172.70	0.00	0.00	0.00	0.00	0.91	29.99
October	511.18	248.83	178.45	0.00	0.00	0.00	0.00	0.33	31.59
November	494.69	240.80	172.70	0.00	0.00	0.00	0.00	0.00	36.46
December	511.18	248.83	178.45	0.00	0.00	0.00	0.00	0.00	35.60
Annual Sum or Average	6018.78	2929.75	2101.13	0.00	0.00	0.00	0.00	3.05	412.59
Minimum of Months	461.71	224.75	161.18	0.00	0.00	0.00	0.00	0.00	29.99
Maximum of Months	511.18	248.83	178.45	0.00	0.00	0.00	0.00	0.95	37.89

Report: **SpaceGainsMonthly** Table of Contents

For: **VESTMASC**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	396.46	192.99	138.40	0.00	0.00	0.00	0.00	0.01	30.24
February	358.10	174.31	125.01	0.00	0.00	0.00	0.00	0.03	28.45
March	396.46	192.99	138.40	0.00	0.00	0.00	0.00	0.07	26.63
April	383.67	186.76	133.94	0.00	0.00	0.00	0.00	0.01	27.00
May	396.46	192.99	138.40	0.00	0.00	0.00	0.00	0.30	27.14
June	383.67	186.76	133.94	0.00	0.00	0.00	0.00	0.20	28.76
July	396.46	192.99	138.40	0.00	0.00	0.00	0.00	0.77	27.16
August	396.46	192.99	138.40	0.00	0.00	0.00	0.00	1.20	26.74
September	383.67	186.76	133.94	0.00	0.00	0.00	0.00	1.05	23.98
October	396.46	192.99	138.40	0.00	0.00	0.00	0.00	0.42	25.16
November	383.67	186.76	133.94	0.00	0.00	0.00	0.00	0.00	29.14
December	396.46	192.99	138.40	0.00	0.00	0.00	0.00	0.01	28.42
Annual Sum or Average	4668.04	2272.25	1629.60	0.00	0.00	0.00	0.00	4.06	328.84
Minimum of Months	358.10	174.31	125.01	0.00	0.00	0.00	0.00	0.00	23.98
Maximum of Months	396.46	192.99	138.40	0.00	0.00	0.00	0.00	1.20	30.24

Report: **SpaceGainsMonthly**

Table of Contents

For: **WCVESTMASC**

Timestamp: **2021-07-11 21:50:38**

Custom Monthly Report

	ZONE PEOPLE TOTAL HEATING ENERGY [kWh]	ZONE LIGHTS TOTAL HEATING ENERGY [kWh]	ZONE ELECTRIC EQUIPMENT TOTAL HEATING ENERGY [kWh]	ZONE GAS EQUIPMENT TOTAL HEATING ENERGY []	ZONE HOT WATER EQUIPMENT TOTAL HEATING ENERGY []	ZONE STEAM EQUIPMENT TOTAL HEATING ENERGY []	ZONE OTHER EQUIPMENT TOTAL HEATING ENERGY []	ZONE INFILTRATION SENSIBLE HEAT GAIN ENERGY [kWh]	ZONE INFILTRATION SENSIBLE HEAT LOSS ENERGY [kWh]
January	50.35	24.51	17.58	0.00	0.00	0.00	0.00	0.50	4.49
February	45.48	22.14	15.88	0.00	0.00	0.00	0.00	0.64	4.42
March	50.35	24.51	17.58	0.00	0.00	0.00	0.00	0.98	4.20
April	48.73	23.72	17.01	0.00	0.00	0.00	0.00	0.96	4.25
May	50.35	24.51	17.58	0.00	0.00	0.00	0.00	1.63	4.71
June	48.73	23.72	17.01	0.00	0.00	0.00	0.00	1.70	4.75
July	50.35	24.51	17.58	0.00	0.00	0.00	0.00	2.23	4.76
August	50.35	24.51	17.58	0.00	0.00	0.00	0.00	2.41	4.82
September	48.73	23.72	17.01	0.00	0.00	0.00	0.00	1.85	4.19
October	50.35	24.51	17.58	0.00	0.00	0.00	0.00	1.51	4.29
November	48.73	23.72	17.01	0.00	0.00	0.00	0.00	0.44	4.42
December	50.35	24.51	17.58	0.00	0.00	0.00	0.00	0.50	4.24
Annual Sum or Average	592.82	288.57	206.95	0.00	0.00	0.00	0.00	15.33	53.55
Minimum of Months	45.48	22.14	15.88	0.00	0.00	0.00	0.00	0.44	4.19
Maximum	50.35	24.51	17.58	0.00	0.00	0.00	0.00	2.41	4.82

of Months									